




Safety Express / Durasafe - Fibreglass Reinforced Stair Nosing with Anti Slip




08 Aug 2020

Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A

Date Tested:	08 Aug 2020
Test Report Number:	0808207
Client Name & Address:	Safety Express / Durasafe - 3 Jellico Drive Scoresby VIC 3179
Test Tile / Project :	Fibreglass Reinforced Stair Nosing with Anti Slip
Surface / Product Tested :	Aluminium Reinforced Stair Nosing with Anti Slip
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Record ambient temperature (°C)	18
Fixed / Unfixed Test :	Yes - Tested in the Direction of Anticipated Pedestrian Traffic
Testing Officer :	Gary Wiltshire
Testing Officer Signature	

Test Results :

	Mean BPN of last 3 swings :	Image of Surface
Specimen 1	69	
Specimen 2	64	

	Mean BPN of last 3 swings :	Image of Surface
Specimen 3	64	
Specimen 4	63	
Specimen 5	64	

Mean BPN Slip Resistance Value (SRV)

65

Using Slider 96 (4S) you have achieved a BPN of P5 = > 54

Accredited for Compliance with ISO/IEC 17025. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A – Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results do not account for Future Wear, Maintenance or Contamination of this surface once in-situ.

Page 1 of 1 - END OF REPORT.