

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	Zhejiang Ruihua Machinery Co., Ltd	Client ID	102557
Company Other Name		Type of Certification	Product Certification; System 5
Certification Standard	AS/NZS 1841.5-2007 : Portable fire extinguishers - Specific requirements for powder type extinguishers		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	10/09/2019	Certification Expiry Date	10/09/2024
Certificate Issue Date	9/05/2015	Certificate Last Update Date	3/05/2021

APPROVED COMPANY/SITE ADDRESS(ES):

Western Industrial Zone, Lingshan Town Yuyao Zhejiang 315460 China

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Unique Certificate Code: 16BC77AE60AC3701CA2586BF00387D17

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER

Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:
In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description / Attributes	Date Approved
P10S	1.0kg dry powder fire extinguisher	Presto	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-112	10-Feb-16
P10C	1.0kg dry powder fire extinguisher	Presto	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-124	10-Feb-16
P10SD	1.0kg dry powder fire extinguisher	Presto	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-125	15-Mar-18
P10SP	1.0kg dry powder fire extinguisher	Presto	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-128	22-Apr-21
P10SHP	1.0kg dry powder fire extinguisher	Presto	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-130	22-Apr-21
P10TP	1.0kg dry powder fire extinguisher	Presto	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-129	22-Apr-29
P15S	1.5kg dry powder fire extinguisher	Presto	1.5 Kg Dry Powder, Rating: 3A:10B:C:E, FERN: 2557.05-114	10-Feb-16
P15P	1.5kg dry powder fire extinguisher	Presto	1.5 Kg Dry Powder, Rating: 3A:30B:C:E, FERN: 2557.05-127	15-Mar-18
P20P	2.0kg dry powder fire extinguisher	Presto	2.0 Kg Dry Powder, Rating: 3A:30B:C:E, FERN: 2557.05-116	10-Feb-16
P25S	2.5kg dry powder fire extinguisher	Presto	2.5 Kg Dry Powder, Rating: 4A:40B:C:E, FERN: 2557.05-118	10-Feb-16
P45S	4.5kg dry powder fire extinguisher	Presto	4.5 Kg Dry Powder, Rating: 6A:60B:C:E, FERN: 2557.05-120	10-Feb-16
P45P	4.5kg dry powder fire extinguisher	Presto	4.5 Kg Dry Powder, Rating: 6A:80B:C:E, FERN: 2557.05-126	10-Feb-16
P90S	9.0kg dry powder fire extinguisher	Presto	9.0 Kg Dry Powder, Rating: 10A:80B:C:E, FERN: 2557.05-122	10-Feb-16
P10S	1.0kg dry powder fire extinguisher	FireWorld	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-212	10-Feb-16
P10C	1.0kg dry powder fire extinguisher	FireWorld	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-224	10-Feb-16



Certification Manager



Model Identification	Model Name	Brand Name	Product Description / Attributes	Date Approved
P10SD	1.0kg dry powder fire extinguisher	FireWorld	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-225	15-Mar-18
P10SP	1.0kg dry powder fire extinguisher	FireWorld	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-228	22-Apr-21
P10SHP	1.0kg dry powder fire extinguisher	FireWorld	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-230	22-Apr-21
P10TP	1.0kg dry powder fire extinguisher	FireWorld	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-229	22-Apr-29
P15S	1.5kg dry powder fire extinguisher	FireWorld	1.5 Kg Dry Powder, Rating: 3A:10B:C:E, FERN: 2557.05-214	10-Feb-16
P15P	1.5kg dry powder fire extinguisher	FireWorld	1.5 Kg Dry Powder, Rating: 3A:30B:C:E, FERN: 2557.05-227	15-Mar-18
P20P	2.0kg dry powder fire extinguisher	FireWorld	2.0 Kg Dry Powder, Rating: 3A:30B:C:E, FERN: 2557.05-216	10-Feb-16
P25S	2.5kg dry powder fire extinguisher	FireWorld	2.5 Kg Dry Powder, Rating: 4A:40B:C:E, FERN: 2557.05-218	10-Feb-16
P45S	4.5kg dry powder fire extinguisher	FireWorld	4.5 Kg Dry Powder, Rating: 6A:60B:C:E, FERN: 2557.05-220	10-Feb-16
P45P	4.5kg dry powder fire extinguisher	FireWorld	4.5 Kg Dry Powder, Rating: 6A:80B:C:E, FERN: 2557.05-226	10-Feb-16
P90S	9.0kg dry powder fire extinguisher	FireWorld	9.0 Kg Dry Powder, Rating: 10A:80B:C:E, FERN: 2557.05-222	10-Feb-16
P10S	1.0kg dry powder fire extinguisher	No name	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-312	10-Feb-16
P10C	1.0kg dry powder fire extinguisher	No name	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-324	10-Feb-16
P10SD	1.0kg dry powder fire extinguisher	No name	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-325	15-Mar-18
P10SP	1.0kg dry powder fire extinguisher	No name	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-328	22-Apr-21
P10SHP	1.0kg dry powder fire extinguisher	No name	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-330	22-Apr-21
P10TP	1.0kg dry powder fire extinguisher	No name	1.0 Kg Dry powder, Rating: 2A:10B:C:E, FERN: 2557.05-329	22-Apr-29
P15S	1.5kg dry powder fire extinguisher	No name	1.5 Kg Dry Powder, Rating: 3A:10B:C:E, FERN: 2557.05-314	10-Feb-16





global-mark®

Model Identification	Model Name	Brand Name	Product Description / Attributes	Date Approved
P15P	1.5kg dry powder fire extinguisher	No name	1.5 Kg Dry Powder, Rating: 3A:30B:C:E, FERN: 2557.05-327	15-Mar-18
P20P	2.0kg dry powder fire extinguisher	No name	2.0 Kg Dry Powder, Rating: 3A:30B:C:E, FERN: 2557.05-316	10-Feb-16
P25S	2.5kg dry powder fire extinguisher	No name	2.5 Kg Dry Powder, Rating: 4A:40B:C:E, FERN: 2557.05-318	10-Feb-16
P45S	4.5kg dry powder fire extinguisher	No name	4.5 Kg Dry Powder, Rating: 6A:60B:C:E, FERN: 2557.05-320	10-Feb-16
P45P	4.5kg dry powder fire extinguisher	No name	4.5 Kg Dry Powder, Rating: 6A:80B:C:E, FERN: 2557.05-326	10-Feb-16
P90S	9.0kg dry powder fire extinguisher	No name	9.0 Kg Dry Powder, Rating: 10A:80B:C:E, FERN: 2557.05-322	10-Feb-16

Comments:

Extinguisher construction complies with standard AS/NZS1841.1 general requirements.

End of the document



Certification Manager